


# Power OFF-delay TIMER


## **Order Code**



### Technical criteria

Rated supply voltage	24 VAC/DC (50/60 Hz)	
Power On time	2 s min	
Operating Temperature	−10 to 55 °C	
Reset Input type	No-voltage input	
Reset input time	0.05 s min	
Output	Contact Output: Instantaneous operation/Time-limit reset/Forced reset (SPDT) 5A at 250 VAC/30 VDC, 0.15A at 125 VDC, resistive load (cosφ = 1) Minimum applied load: 10mA at 5 VDC (failure level: P, reference value) Contact materials: Ag-alloy	
Accuracy of operating Time	±0.2% Full Scale max. (±0.2% FS ±10 ms max. in ranges of 0.6 and 1.2 s)	
Setting error	±5% Full Scale ±50 ms max.	
Operation start voltage	30% max. of rated voltage	
Influence of voltage	±0.2% Full Scale max. (±0.2% FS ±10 ms max. in ranges of 0.6 and 1.2 s)	
Influence of temperature	±1% Full Scale max. (±1% FS ±10 ms max. in ranges of 0.6 and 1.2 s)	
Operating mode	Power OFF-delay with a reset input	
Safety Standards	l.,	he most recent information on models that have been fied for safety standards, refer to your OMRON website.

#### **Nomenclature**




## Time range

	Time unit	M-series
Scale number (max.)		min (minute)
0.6	Set time range	0.05 to 0.6
1.2		0.12 to 1.2
6	Set time range	0.6 to 6
12		1.2 to 12
Min. power ON time		2 s min.
Time-up operation repeat period		3 s min.
Forced-reset repeat period		3 s min.

Note: 1. If the above minimum power ON time is not secured, the H3CR may not operate. Be sure to secure the above minimum power ON time.

2. Do not use the Timer with a repeat period of less than 3 s. Doing so may result in abnormal heating or burning.

## **Timing Chart**



t: Set time

Rt: Minimum power ON time (2 s min.)

If the power ON time is less than this value, the Timer may not operate (i.e., output may not turn ON).

Note: If the power is turned ON until the set time is up, the timer will be retriggered.

#### **Accessories**



OMRON Corporation Industrial Automation Company Kyoto, JAPAN

Contact: www.ia.omron.com

Regional Headquarters
OMRON EUROPE B.V.
Wegalaan 67-69, 2132 JD Hoofddorp
The Netherlands
Tel: (31) 2356-81-300/Fax: (31) 2356-81-388
https://industrial.omron.eu/en/home

OMRON ELECTRONICS Burhaniye Mah. Tunuslu Mahmut Paşa Cad. No:10 34676 Üsküdar, İstanbul Tel: (90) 216-556-5130/Fax: (90) 216-556-5160

https://industrial.omron.com.tr

© OMRON Corporation 2018 All Rights Reserved. In the interest of product improvement, specifications are subject to change without notice.

Cat. No. L171-E1-01

0318 (0318)